




PROJECT OUTCOME CERTIFICATE


Name of Project	Water Supply to Sikarchandi slum area in ward No.02 including Patia, Jali Munda Sahi and Banphool slum of BMC.(AMRUT/OD/BHUBANESWAR/WS/59)		
Project code	(AMRUT/OD/ BHUBANESWAR/ WS/59)		
Project components (to be filled in by PHEO)			
Intake (dia.& cap. In MLD)	-		
WTP (Cap.in MLD)	-		
Production well(Nos.& Cap.in ML)	Production well-5 Nos.		
Storage ESR (Nos. & Cap. In ML)GSR (Nos. & Cap. In MI)	-		
Distribution network (length in Km)	100mm dia DI K7- 6.956 Km. 150mm dia DI K7- 1.598 Km., 200mm dia DI K7-.546 Km.		
Outcome (Pre & post target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	post Implementation - Target	Post Implementation- Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCD*)	-	135 lpcd	135 lpcd
Storage (ML)	-	-	-
Increase in Supply Duration (Hrs)	1 hr. (Stand Post)	2 hr. (house hold)	2 hr. (house hold)
Household Coverage In project area	0	2363 Nos.	2045 Nos.
Equity & Adequacy (Adequate quantity reaches last house in tail end)	Yes	v	Please Tick the appropriate box
	No		Please Tick the appropriate box
* Computation of LPCD = (Daily quantity supplied to project area in ltr)/(total population in project area)			


Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.


Signature, Name & Designation

	 City Engineer Municipal Corporation	 15/7/19 Collector's Representative DRDA Khorda	 15/7/19 Executive Engineer P.H. Division Bhubaneswar Representative
Councillor(s)/ Corporation(s)			

Note: This certification cannot be treated as confirmation or approval of executive quantity


 15/7/19
 Asst. Manager
 WATCO Section
 Madira Vihar


 15/7/19
 Asst. Manager
 WATCO, Section
 Saelein Vihar
 Bhubaneswar


 15/7/19
 Manager
 WATCO, Sub-Division
 Chandrasekharpur
 Bhubaneswar