





PROJECT OUTCOME CERTIFICATE

Name of Project	Improvement of WS to 51 nos. slum in Sector area						
Project code	(AMRUT/OD/ROURKELA/WS/09)						
Project components (to be filled in by PHEO)							
Intake (dia. & Cap. in MLD)							
WTP (Cap. in MLD)							
Production well (Nos. & Cap. in ML)							
Storage ESR (Nos. & Cap. in ML)	0.60 ML						
GSR (Nos. & Cap. in ML)							
Distribution network (length in Km)	29.30 Km						
Outcome (Pre&post target to be entered by PHEO in sync. with monitoring tool)							
Description	Pre Implementation	Post Implementation - Target	Post Implementation -Actual(to be verified & recorded by the team)				
Increase in Supply Quantity (LPCD*)		135	135				
Storage (ML)		0.60	0.60				
Increase in Supply Duration (Hrs)		2.00	2.00				
Household Coverage In project area	Total no. of houses in the project area -6313 Existing connections if any - Nil	Targeted no. of New connections - 4250	Actual no. of new Connections - 445				
Equity & Adequacy (Adequate quantity reaches last house in tail end)	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Yes</td> <td style="width: 50%; text-align: center;">✓</td> </tr> <tr> <td>No</td> <td></td> </tr> </table>		Yes	✓	No		Please Tick the appropriate box
Yes	✓						
No							
<i>*Computation of LPCD =(Daily quantity supplied to project area in ltr)/(total population in project area)</i>							

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature, Name& Designation

 Councillor(s) Corporator(s)	 Deputy Commissioner Official Municipal Corporation	 Project Director, DUDA Representative	 PHEO Representative
---	--	--	---

Note: This certification cannot be treated as confirmation or approval of execution quantity