



PROJECT OUTCOME CERTIFICATE

Name of the Project	Augmentation of water supply to Bhanjanagar NAC under state plan 2017-18.	
Project Code		
Project components <small>(To be filled only by NHED)</small>		
Intake (dia & Cap. In MLD)	-	
WTP (Cap. In MLD)	-	
Production well (Nos. & Cap. In ML)	-	
Storage	-	
ESR (Nos. & Cap. In ML)	-	
GSR (Nos. & Cap. In ML)	-	
Distribution network (length in Km)	1 no 0.45 ML capacity(GSR)	
	150mm DI(K-7) pipe line 1.44 k.m. & 110mm PVC pipe line 0.650k.m.	

Outcome <small>(Pre & Post Target to be entered by PHEO in YOC. With monitoring Cost)</small>						
Description	Pre Implementation	Post Implementation - Target				
Increase in supply Quantity (LPCD*)	108	118 Lpcd				
Storage (ML)	1.05 ML	1.50 ML				
Increase in supply duration (Hrs)	5 hrs	5 hrs				
Household coverage in project area	4546 nos Households & 1821 nos Existing connections.	800 Nos.				
Equity & Adequacy <i>(Adequate quantity reaches last houses in tail end)</i>	Enter Total no. of houses in the project area & existing connections (if any)	(Enter targeted no. of New connections)				
		Providing of house connections are under progress & 577 nos of house connection completed.				
*Computation of LPCD=(Daily quantity supplied to project area in ltr)/(total population in project area)		Please Tick the appropriate box				
Certified that the above project has been completed and put to service. The information provided herein are correct to the best of our knowledge.		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;">Yes</td> <td style="width: 50%; text-align: center;">V</td> </tr> <tr> <td style="width: 50%; text-align: center;">No</td> <td style="width: 50%; text-align: center;"></td> </tr> </table>	Yes	V	No	
Yes	V					
No						

Signature, Name & Designation

Councillor(s)/ Corporator(s)			
Commissioning Officer's representative	Commissioning Officer A. C. Bha & Executive Officer's representative	Tahasildar Collector's representative	Asst. Executive Engineer P.H. Sub-Division Bhanjanagar PHEO
This certificate cannot be treated as confirmation or approval of execution quantity.			