





PROJECT OUTCOME CERTIFICATE

Name of Project	con. of 2 lakh ltr OGR at Badhe & laying of distribution system in Greda Nahi, Choudwar						
Project code	B2208, Mahapada in Choudwar Municipality.						
Project components (to be filled in by PHEO)							
Intake (dia. & Cap. in MLD)							
WTP (Cap. in MLD)							
Production well (Nos. & Cap. in ML)							
Storage ESR (Nos. & Cap. in ML)	OGR - 2.0 lakh ltr capacity						
GSR (Nos. & Cap. in ML)							
Distribution network (length in Km)	150 mm dia. DI pipe line - 797.50 mtrs. 100 mm dia. DI pipe line - 616.0 mtrs.						
Outcome (Pre & post target to be entered by PHEO in sync. with monitoring tool)							
Description	Pre Implementation	Post Implementation - Target	Post Implementation - Actual (to be verified & recorded by the team)				
Increase in Supply Quantity (LPCD*)	< 40 lpcd.	7100 lpcd.	7150 lpcd.				
Storage (ML)	No storage	2.0 lakh ltr	2.0 lakh ltr.				
Increase in Supply Duration (Hrs)	2 hours	4 hours	4 hours.				
Household Coverage In project area	12 nos of house connection (Enter Total no. of houses in the project area & existing connections if any)	80 nos are being giving. (Enter targeted no. of New connections)	(Enter actual no. of new Connections)				
Equity & Adequacy (Adequate quantity reaches last house in tail end)	<table border="1" style="width: 100%; text-align: center;"> <tr> <td>Yes</td> <td>✓</td> </tr> <tr> <td>No</td> <td></td> </tr> </table>		Yes	✓	No		Please Tick the appropriate box
Yes	✓						
No							
*Computation of LPCD = (Daily quantity supplied to project area in ltr)/(total population in project area)							

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature, Name & Designation

 22-9-18	 22/9/18	 22/9/18	 22/9/18
Chairperson Municipality	Executive Officer Municipality	Collector's Representative	Assistant Engineer, P.H. Section Representative

Note: This certification cannot be treated as confirmation or approval of execution quantity