




PROJECT OUTCOME CERTIFICATE

Name of the Project Project Code	Development of source at Sunambo street of Aska NAC		
Project components			
(To be filled in by PHEO)			
Intake (dia & Cap. In MLD)	1 no. (4.5, mtr dia x 20 mtr depth & 2 MLD)		
WTP (Cap. In MLD)	—		
Production well (Nos. & Cap. In ML)	—		
Storage ESR (Nos. & Cap. In ML)	1 no (1.00 lakh ltr capacity i.e.0.10 MLD)		
GSR (Nos. & Cap. In ML)	—		
Distribution network (length in Km)	—		
Outcome (Pre & post target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation - Target	Post Implementation- Actual (To be verified & recorded by the teram)
Increase in supply Quantity (LPCD*)	105 Lpcd	120 Lpcd	
Storage (ML)	0.725 MLD	0.825 MLD	
Increase in supply duration (Hrs)	6 Hours	6 Hours	
Household coverage in project area	4581 Households & 2517 existing house connection	1000 nos (Enter targeted no. of New connections)	Providing of house connections are under progress & 925 nos of house connections provided (Enter actual no. of new connections)
Equity & Adequacy (Adequate quantity reaches last houses in tail end)			Please Tick the appropriate box
*Computation of LPCD=(Daily quantity supplied to project area in ltr)/(total population in project area)	Yes	No	
Certified that the above project has been completed and put to service. The information provided herein are correct to the best of our knowledge.			
Signature, Name & Designation			
	 Executive Officer Commissioner, Aska Officer's representative	 Collector's Representative PHEO	 Assistant Executive Engineer PHEO Division, Aska PHEO Representative
Councillor(s)/ Corporator(s)	Note: This certificate cannot be treated as confirmation or approval of execution quantity.		