

PROJECT OUTCOME CERTIFICATE

Name of the Project	IMPROVEMENT OF WATER SUPPLY TO DASA SAHI, BAURISAHU, LAXMIPUR & BRAJAMOHANPUR RAMBHA UNDER STATE PLAN 2017 - 18.		
Project Code			
Project components (To be filled in by PHEO)			
Intake (dia & Cap. In MLD)	-		
WTP (Cap. In MLD)	-		
Production well (Nos. & Cap. In ML)	1 No. & Capacity 0.08 ML		
Storage ESR (Nos. & Cap. In ML)	-		
GSR (Nos. & Cap. In ML)	-		
Distribution network (length in Km)	Laying of 110 mm dia PVC pipe = 0.442 Kms.		
Outcome (Pre & post target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation - Target	Post Implementation- Actual (To be verified & recorded by the teram)
Increase in supply Quantity (LPCD*)	60 Lpcd	80 Lpcd	<i>Rate of supply has be increased.</i>
Storage (ML)	--	-	—
Increase in supply duration (Hrs)	1.00 hrs	2.00 hrs	<i>Hours of supply has been enhanced.</i>
Household coverage in project area	381 nos Households & 60 nos Existing connections. <small>(Enter Total no. of houses in the project area & existing connections if any)</small>	321 Nos. <small>(Enter targeted no. of New connections)</small>	<i>Providing of house connections are under progress.</i> <small>(Enter actual no. of new connections)</small>
Equity & Adequacy <i>(Adequate quantity reaches last houses in tail end)</i>	Yes		Please Tick the appropriate box
	No		
*Computation of LPCD=(Daily quantity supplied to project area in ltr)/(total population in project area)			√

Certified that the above project has been completed and put to service. The information provided herein are correct to the best of our knowledge.

Signature, Name & Designation

<i>Sudam Gouda</i> Councillor-3	<i>M Das</i> 07.07.2018	<i>S. C.</i> 07.07.2018	<i>D. Sumbary</i> 07/07/2018
Councillor(s)/ Corporator(s)	Commissioner/Executive M.A.C., Rambha.	Collector/Resident Khalikote, Ganjam	Assistant Executive Engineer P.H. Sub-Div. PHEO Rambha Representative

Note: This certificate cannot be treated as confirmation or approval of execution quantity.