




PROJECT OUTCOME CERTIFICATE

Name of Project	Improvement of water supply including extension of distribution network to Itua and its adjoining areas of w .no. 13 in Soro Municipality.(Project-3)		
Project Code			
Project Components (to be filled in by PHEO)			
Intake (dia. & cap. in MLD)	—		
WTP (cap. in MLD)	—		
Production Well (Nos. & Cap in ML)	01 No.		
Storage ESR (Nos. & Cap in ML) GSR (Nos. & Cap in ML)	—		
Distribution network (length in Km)	1.73 Km (100mm dia. DI K-7 Pipe = 1.34 Km.) (150mm dia. DI K-7 Pipe = 0.39 Km.)		
Outcome (Pre & Post target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation-Target	Post Implementation Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCD*)	68	73	125
Storage (ML)	—	—	—
Increase in Supply Duration (Hrs)	—	—	—
Household Coverage in project area	426 and 66 (Enter Total no. of house in the project area & existing connections if any)	360 (Enter targeted no. of New connections)	04 (Enter actual no. of new connections)
Equality & Adequacy (Adequate quantity reaches last house in tail end)	Yes	<input checked="" type="checkbox"/>	Please Tick the appropriate box
	No	<input type="checkbox"/>	
*Computation of LPCD= (Daily quantity supplied to project area in ltr)/total population in project area)			

Certificate that the above project has been completed and put to service. The informations provided herein are correct to best of our knowledge.

Signature, Name & Designation

	 Executive Officer Soro Municipality Officer's representative	 Asst. Engineer (Tech) P.H. Sec. Soro Representative	 Asst. Engineer P.H. Sec. Soro Representative
Councilor(s)/ Corporator(s)			

Note: this Certificate cannot be treated as conformation or approval of execution quantity.