

PROJECT OUTCOME CERTIFICATE

Name of the Project	Improvement of water supply to Scarcity pockets of Aska NAC (Taluka Road, Gandhi Nagar, Pakalapali, W.No. 15,18		
Project Code			
Project components			
(To be filled in by PHEO)			
Intake (dia & Cap. In MLD)	-		
WTP (Cap. In MLD)	-		
Production well (Nos. & Cap. In ML)	2 no / 0.17ML(0.085ML each)		
Storage ESR (Nos. & Cap. In ML)	-		
GSR (Nos. & Cap. In ML)	-		
Distribution network (length in Km)			
Outcome			
(Pre & post target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation - Target	Post Implementation- Actual (To be verified & recorded by the team)
Increase in supply Quantity (LPCD*)	105	121 Lpcd	<i>16 lpcd has been increased for the total NAC area</i>
Storage (ML)	0.725ML	0.725ML	
Increase in supply duration (Hrs)	6 hours	6 hours	
Household coverage in project area	200 nos Households & 4 nos Existing connection nil. (Enter Total no. of houses in the project area & existing connections if any)	196 (Enter targeted no. of New connections)	<i>House hold water supply connections are being provided</i> (Enter actual no. of new connections)
Equity & Adequacy (Adequate quantity reaches last houses in tail end)		Yes v No	Please Tick the appropriate box
*Computation of LPCD=(Daily quantity supplied to project area in ltr)/(total population in project area)			

Certified that the above project has been completed and put to service. The information provided herein are correct to the best of our knowledge.

Signature, Name & Designation

30.6.18 <i>Kailesh Pordhon</i> W.No-10 Councillor	<i>[Signature]</i> 30/6/18 Executive Officer	<i>[Signature]</i> 30.06.18 Tahasildar	<i>[Signature]</i> 30/6/18 Assistant Executive Engineer P.H. Sub Division, Aska PHEO
Councillor(s)/ Corporator(s)	Commissioner's/Executive Officer's representative	Collector's Representative ASKA (Ganjam)	Representative

Note: This certificate cannot be treated as confirmation or approval of execution quantity.