

PROJECT OUTCOME CERTIFICATE

Name of the Project IMPROVEMENT OF WATER SUPPLY TO SCARCITY POCKETS OF NIRMALAJHARA AND AUROBINDANAGAR IN WARD NO. 1, KHALLIKOTE N.A.C UNDER STATE PLAN, 2017 - 18

Project Code _____ **Project components**
(To be filled in by PHEO)





Intake (dia & Cap. In MLD)	-
WTP (Cap. In MLD)	-
Production well (Nos. & Cap. In ML)	1no. & 0.04ML
Storage ESR (Nos. & Cap. In ML)	-
GSR (Nos. & Cap. In ML)	1no. & 0.10ML
Distribution network (length in Km)	Laying of 110mm OD pvc 0.16 K.M & 0.200K.M (110mm. HDPE)

Outcome
(Post target to be entered by PHEO in sync. with monitoring tool)

Description	Pre Implementation	Post Implementation - Target	Post Implementation- Actual (To be verified & recorded by the team)
Increase in supply Quantity (LPCD*)	58	135	Per capita supply increased
Storage (ML)	NIL	0.10	Construction of 1no. UGR near Stadium
Increase in supply duration (Hrs)	1hour	2hours	Daily supply hour enhanced
Household coverage in project area	No. of Households 142 & No. of existing connections. 26nos. <small>(Enter Total no. of houses in the project area & existing connections)</small>	116nos.	Providing of house service connections is in progress <small>(Enter no. of no. of house connections)</small>
Equity & Adequacy (Adequate quantity reaches last houses in tail end)		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Please Tick the appropriate box
*Computation of LPCD=(Daily quantity supplied to project area in ltr)/(total population in project area)			

Certified that the above project has been completed and put to service. The information provided herein are correct to the best of our knowledge.

Signature, Name & Designation

 Councillor Ward No. 1 N.A.C. Khallikote Corporator(s)	 Commissioner's/Executive Officer's representative N.A.C. Khallikote (Gm)	 TAHASILDAR Collector's Representative Khallikote (Gm.)	 Assistant Executive Engg. P.H. Sub-Office PHEO Chattrap Representative
--	--	---	---

Note: This certificate cannot be treated as confirmation or approval of execution quantity.