




PROJECT OUTCOME CERTIFICATE

| Name of the Project | Improvement of water supply to Maradisahi and adjoining areas (Uncovered and scarcity pockets) of Kodala N.A.C. under STATE PLAN 2017 - 18 | | |
|--|--|--|--|
| Project Code | | | |
| Project components (To be filled in by PHEO) | | | |
| Intake (dia & Cap. In MLD) | - | | |
| WTP (Cap. In MLD) | - | | |
| Production well (Nos. & Cap. In ML) | 3 nos (0.08 ML) | | |
| Storage ESR (Nos. & Cap. In ML) | - | | |
| GSR (Nos. & Cap. In ML) | 1 no 0.04 ML capacity(GSR) | | |
| Distribution network (length in Km) | 0.45KM | | |
| Outcome (Pre & post target to be entered by PHEO in sync. With monitoring tool) | | | |
| Description | Pre Implementation | Post Implementation - Target | Post Implementation- Actual (To be verified & recorded by the team) |
| Increase in supply Quantity (LPCD*) | 82 Lpcd | 87 Lpcd | |
| Storage (ML) | 0.945 ML | 0.985 ML | |
| Increase in supply duration (Hrs) | 2.0 hrs | 2.0 hrs | |
| Household coverage in project area | 300 nos Households <small>(Enter Total no. of houses in the project area & existing connections if any)</small> | 300 Nos. <small>(Enter targeted no. of New connections)</small> | 47 Nos <small>(Enter actual no. of new connections)</small> |
| Equity & Adequacy <i>(Adequate quantity reaches last houses in tail end)</i> | Yes No | V | Please Tick the appropriate box |
| *Computation of LPCD=(Daily quantity supplied to project area in ltr)/(total population in project area) | | | |

Certified that the above project has been completed and put to service. The information provided herein are correct to the best of our knowledge.

Signature, Name & Designation

| | | | |
|------------------------------|--|--|---|
| |  09/11/18 Executive Officer Kodala N.A.C. |  09/11/18 Collector's Representative Kodala N.A.C. |  09/11/18 Assistant Executive Engineer P.H. Sub Division, Aska PHEO Representative |
| Councillor(s)/ Corporator(s) | Commissioner's Representative | Collector's Representative | Assistant Executive Engineer P.H. Sub Division, Aska PHEO Representative |

Note: This certificate cannot be treated as confirmation or approval of execution quantity.