

PROJECT OUTCOME CERTIFICATE

Laying of balance distribution network, construction production well, Pump house, Power supply and commissioning of production well in ward no 6, 7, 8, 17, 18, 19, 20, and 21 of Jagatsinghpur Municipality."

State Plan

Project components Laying of 150mm dia D.I pipe-5200mtr, 100mm dia D.I pipe-9500 mtr, 200mm dia production well- 2nos, 25KVA transformer with substation-2No, Construction of Pump house -2 Nos., Fixing of D.I S.V 150mm -6 Nos & 100 mm dia-15 Nos and installation of 15 H.P Submersible pump -2sets (stand by 2sets)
(to be filled in by FHEO)

Intake (dia. & cap. In MLD)	Nil
WTP (Cap. In MLD)	Nil
Production well (Nos. & Cap. In ML)	Nil
Storage	Nil
ESR (Nos. & Cap. In ML)	Nil
GSR (Nos. & Cap. In ML)	Nil
Distribution network (length in km)	14.7

& post target to be entered by FHEO in sync. With monitoring tool (Pre

Description	Pre Implementation	Post Implementation - Target	Post Implementation - Actual (to be verified & recorded by the team)
Increase in supply Quantity (LPCD*)	Nil	160	
Storage (ML)	Nil	Nil	
Increase in supply Duration (Hrs)	Nil	8hours	
Household Coverage In project area	(Enter Total no of houses in the project area & existing connections if any) 350Nos	Enter targeted no of New connections) 302Nos	Enter actual no of new connections)
Equity & adequacy quantity reaches last house in tail end)	(Adequate	Yes	Please Tick the appropriate box
		No	

*Computation of LPCD = (Daily quantity supplied to project area in ltr)/(total population in project area)

Certified that the above project has been completed and put to service . The information provided here in are correct to best of our knowledge.

Councillor(s)/ Corporator(s)	 Commissioner, Jagatsinghpur Municipality Office Jagatsinghpur Municipality	 Collector's Representative	 FHEO Representative P.H. Sub-Division, Jagatsinghpur
			1.1.2019

Note: This certification cannot be treated as confirmation or approval of execution quantity