





PROJECT OUTCOME CERTIFICATE

Name of Project	Replacement of 1 No 40 HP pump set (H- 40 mtrs, Q-65 Lps) with control panel, cable, MCCB etc. complete at clear water pump house near over head tank, Rajgangpur		
Project code	DMF		
Project components <i>(to be filled in by PHEO)</i>			
Intake (dia. & Cap. in MLD)			
WTP (Cap. in MLD)			
Production well (Nos. & Cap. in ML)			
Storage ESR (Nos. & Cap. in ML)			
GSR (Nos. & Cap. in ML)			
Distribution network (length in Km)			
Outcome <i>(Pre&post target to be entered by PHEO in sync. with monitoring tool)</i>			
Description	Pre Implementation	Post Implementation - Target	Post Implementation -Actual(to be verified & recorded by the team)
Increase in Supply Quantity (LPCD*)	60	70	70
Storage (ML)	--	--	--
Increase in Supply Duration (Hrs)	0.50	1.00	1.00
Household Coverage In project area	N/A <i>(Enter Total no. of houses in the project area & existing connections if any)</i>	N/A <i>(Enter targeted no. of New connections)</i>	N/A <i>(Enter actual no. of new Connections)</i>
Equity & Adequacy <i>(Adequate quantity reaches last house in tail end)</i>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	<i>Please Tick the appropriate box</i>
*Computation of LPCD =(Daily quantity supplied to project area in ltr)/(total population in project area)			

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature, Name & Designation

 Anand Kumar Baidya Councillor(s)/ Corporator(s) Ward No.-10 Rajgangpur Municipality	 S. Parkash Commissioner's/Executive Oficer/Representative Rajgangpur Municipality	 P.K. Mahanta Chief Executive Officer District Representative Sundargarh	 P.H. Sub-Division Assistant Executive Engineer Sundargarh
---	--	--	---

Note: This certification cannot be treated as confirmation or approval of execution quantity


Executive Officer
RAJGANGPUR MUNICIPALITY