

## PROJECT OUTCOME CERTIFICATE

Name of Project	sinking of 2.nos production well with pump house & Pump set with electrification & Laying of pipe line at Dengaguda & Tentuliguda village under Koraput Municipality under State plan 2017-18		
Project Code	Project Components (to be filled in by PHEO)		
Intake (dia & Cap. In M.L.D)	-----		
WTP (Cap.in ML)	-----		
Production well (Nos & Cap in ML)	2 nos :- 65 lpm		
Storage ESR (Nos. & Cap in ML) GSR (Nos. & Cap in ML)	2 nos :- 0.06 ML		
Distribution network (length in Km)	0.43 km.		
<b>Outcome</b> (Pre & post target to be entered by PHEO in sync. With monitoring tool)			
Description	Pre Implementation	Post Implementation Target	Post Implementation Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCD)	Nil	135 LPCD	130 LPCD
Storage (ML)	-----	0.06 ML	0.06 ML
Increase in supply Duration (Hrs)	Nil	1Hr 30 minutes	1Hr 30 minutes
Household coverage in project area	90 (Enter total no of houses in the project are & existing connections if any)	50 (Enter targeted no of New connections)	(Enter actual no of new connection)
Equity & Adequacy (Adequate quantity reaches last house in tail end)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Please tick the appropriate box
*Computation of LPCD = (Daily quantity supplied to project area in ltr) total population in project area.			

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

**Signature Name & Designation**

<p><i>proclam)um</i>  <i>ev-110-16</i>  <i>(Councillor)</i></p>	<p><i>21/01/19</i></p>	<p><i>Rm</i></p>
Councillor(s)/ Corporate (s)	Commissioner's / <b>*EXECUTIVE OFFICER KORAPUT MUNICIPALITY</b>	Collector's Representative DUDA, KORAPUT
		PHEO Representative

Note : This Certification cannot be treated as confirmation of approval of execution quantity