





PROJECT OUTCOME CERTIFICATE

Name of Project	Sinking of production well with pump house & Pump set with electrification & laying of pipe line at Dangadeula under Koraput Municipality under Koraput Municipality under State action plan for the year 2017-18.		
Project Code			
Project Components <i>(to be filled in by PHEO)</i>			
Intake (dia & Cap. In MLD)	-----		
WTP (Cap.in ML)	-----		
Production well (Nos & Cap in ML)	2 nos :- 130 lpm		
Storage ESR (Nos. & Cap in ML) GSR (Nos. & Cap in ML)	1 no :- 0.05 ML		
Distribution network (length in Km)	0.285 km.		
Outcome <i>(Pre & post target to be entered by PHEO in sync. With monitoring tool)</i>			
Description	Pre Implementation	Post Implementation Target	Post Implementation Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCD)	-----	135 LPCD	75 LPCD
Storage (ML)	0.05 ML	0.05 ML	0.05 ML
Increase in supply Duration (Hrs)	-----	1 Hrs	1 Hrs
Household coverage in project area	62 <i>(Enter total no of houses in the project are & existing connections if any)</i>	28 <i>(Enter targeted no of New connections)</i>	<i>(Enter actual no of new connection)</i>
Equity & Adequacy (Adequate quantity reaches last house in tail end)	<input type="checkbox"/> Yes <input type="checkbox"/> No		<i>Please tick the appropriate box</i>
*Computation of LPCD = (Daily quantity supplied to project area in ltr) total population in project area.			

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature Name & Designation:

 Gunder Bhojha Executive Officer Koraput Municipality	 J. K. Dey Deputy Executive Officer Koraput Municipality	 P. K. Dey Project Director Collector's Office Koraput Municipality	 PHEO Representative
---	---	--	--

Note : This Certification cannot be treated as confirmation of approval of execution quantity