

PROJECT OUTCOME CERTIFICATE





Name of the Project	SINKING OF PRODUCTION WELL, CONSTRUCTION OF UGR AND LAYING OF PIPE LINE IN UN-COVERED AREA OF DAMODARPUR, GANJAM NAC.		
Project Code			
Project components			
(To be filled in by PHEO)			
Intake (dia & Cap. In MLD)	-		
WTP (Cap. In MLD)	-		
Production well (Nos. & Cap. In ML)	1 No. & 0.20 M.L		
Storage	-		
ESR (Nos. & Cap. In ML)			
GSR (Nos. & Cap. In ML)	1 no 0.15 ML capacity (GSR)		
Distribution network (length in Km)	Laying of 110MM OD PVC pipe line for 0.276 K.M		

Outcome

(To be post target to be entered by PHEO in sync. With monitoring tool)				
Description	Pre Implementation	Post Implementation - Target	Post Implementation - Actual (To be verified & recorded by the teram)	
Increase in supply Quantity (LPCD*)	75 Lpcd	100 Lpcd	Rate of supply enhanced & providing of house connection	
Storage (ML)	0 ML	0.15 ML	U.G.R. newly constructed	
Increase in supply duration (Hrs)	2.00 hrs	2.00 hrs	Residual pressure increased.	
Household coverage in project area	464 nos Households & 249 Nos. Existing connections.	215 Nos.	Providing of house connections are under progress.	
	(Enter Total no. of houses in the project area & existing connections if any)	(Enter targeted no. of New connections)	(Enter actual no. of new connections)	
Equity & Adequacy (Adequate quantity reaches last houses in tail end)		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Please Tick the appropriate box	
*Computation of LPCD=(Daily quantity supplied to project area in ltr)/(total population in project area)				

Certified that the above project has been completed and put to service. The information provided herein are correct to the best of our knowledge.

Signature, Name & Designation

 Councillor N-11	 Commissioner's/Executive Officer's representative	 Collector's Representative	 PHEO Representative
Councillor(s)/Corporator(s)	Commissioner's/Executive Officer's representative	Collector's Representative	Assistant Executive Engineer P.H. Sub-PHEO, Chatrapur

Note: This certificate cannot be treated as confirmation or approval of execution quantity.