





PROJECT OUTCOME CERTIFICATE

Name of Project	W/S to Panasalli of ward NO-11 (un covered & cavity pockets) of Balliguda NAC under S.P-2017-18	
Project code		
Project components (to be filled in by PHEO)		
Intake (dia. & Cap. in MLD)	—	
WTP (Cap. in MLD)	—	
Production well (Nos. & Cap. in ML)	2 nos & 0.063 ML.	
Storage ESR (Nos. & Cap. in ML)		
GSR (Nos. & Cap. in ML)	Sump - 0.03 ML.	
Distribution network (length in Km)	0.435 Km (110mm dia. HDPE PIPE)	

Outcome (Pre & post target to be entered by PHEO in sync. with monitoring tool)			
Description	Pre Implementation	Post Implementation - Target	Post Implementation - Actual (to be verified & recorded by the team)
Increase in Supply Quantity (LPCD*)		135 L P.C.D.	135 L P.C.D.
Storage (ML)		0.03 ML	0.03 ML.
Increase in Supply Duration (Hrs)		2.0 hrs.	2.0 hrs.
Household Coverage In project area	6 nos / 0 (Enter Total no. of houses in the project area & existing connections if any)	25 nos (Enter targeted no. of New connections)	— (Enter actual no. of new Connections)
Equity & Adequacy (Adequate quantity reaches last house in tail end)		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Please Tick the appropriate box
*Computation of LPCD = (Daily quantity supplied to project area in ltr) / (total population in project area)			

Certified that the above project has been completed and put to service. The information provided herein are correct to best of our knowledge.

Signature, Name & Designation

 Councilor	 Executive Officer	 Sub-Collector	 PHEO Representative
Word No - 112-11-18 NAC Balliguda Councillor(s) Corporator(s)	Commissioner's Office, NAC, Balliguda	Sub-Collector Representative BALLIGUDA	PHEO Representative Engineer PH. Section, G.Udayagiri

Note: This certification cannot be treated as confirmation or approval of execution quantity